

No:23/2021

CERTIFICATE

This is to certify that the Fire Extinguishers installed at Rajashree S.M. Memorial School, East Kadungalloor, UC College, P.O., Aluva has been inspected by me and found functional. Fire fighting vehicles / Personnel can easily access the compound in case of an emergency.

Aluva

06/01/2021.



A handwritten signature in black ink, appearing to be 'S. S. S.', written over a circular stamp.

Station Officer

Fire & Rescue Station, Aluva



Certificate

No. FFC/783/2024

Date: 23-07-2024

To

RAJASHREE SCHOOL,
KADUNGALLOOR,
ALUVA,
ERNAKULAM.

This is to certify that the following fire extinguishers have been refilled and Serviced on 24-7-2024 and valid till 23-07-2025.

SI. No	Type of fire extinguisher	Capacity	Class of fire	Nos	Date of refilling	Next due of service
1	ABC	2 KG	A/B/C	11	24-07-2024	23-07-2025
2	DCP	10 KG	B/C	1	24-07-2024	23-07-2025

For Firefly Enterprises,

Authorized Signature

